

OFFICE OF THE CHIEF CHEMIST
PUBLIC HEALTH ENGINEERING DEPARTMENT LABORATORY, GANDHI NAGAR, JAIPUR
REPORT OF THE CHEMICAL EXAMINATION OF WATER

No: Lab/Sup.Chem. (HM) / Jaipur (City) /2022-2023/ 11007

Date: 13/3/2023

To,

Principal
 Kendriya Vidyalaya No-7
 CISF . Jaipur
 Jaipur.
 Date of Receipt 10-03-2023

The Sample was not Collected
 by this Laboratory

Not Valid for water
 quality & Legal Cases

Particulars	value as per I.S.: 10500/2012		Tube Well Water Kendriya Vidyalaya No- 7 CISF . Jaipur
	Requirement (Acceptable Limit)	Permissible Limit in the absence of Alternate Source	Jaipur
Village / Town			10-03-2023
Date of Collection			P - 119
Lab. Sample No.			7.41
1. pH	6.5-8.5	6.5-8.5	NIL
2. Turbidity (NTU)	1	5	None
3. Colour (Hazen units)	5	15	U.O.
4. Odour	Un Objectionable		270
5. Total Alkalinity(as CaCo3) mg/l	200	600	270
6. Total Hardness (as CaCo3) mg/l	200	600	40
7. Calcium (as Ca) mg/l	75	200	41
8. Magnesium (as Mg) mg/l	30	100	80
9. Chloride (as Cl-) mg/l	250	1000	55
10. Nitrates (as NO3-) mg/l	45	45	30
11. Sulphate (as SO4-2) mg/l	200	400	630
12. Total Dissolved Solids mg/l	500	2000	0.46
13. Fluoride mg/l	1.00	1.5	NIL
14. Iron mg/l	1.0	No Relaxation	NIL
15. Arsenic mg/l	0.01	No Relaxation	NIL

Remark- 1. All chemical parameters except pH are in mg/L
 2. Tested Results Relate only to The Samples send by you

13/3/2023

Superintending Chemist (Heavy Metal)
 P.H.E.D. Laboratory, Jaipur

No: Lab/Sup.Chem. (HM) / Jaipur (City) /2022-2023/

Date:

Copy to:- 1. The Chief Chemist, PHED Raj. Jaipur

Superintending Chemist (Heavy Metal)
 P.H.E.D. Laboratory, Jaipur



OFFICE OF THE CHIEF CHEMIST
PUBLIC HEALTH ENGINEERING DEPARTMENT, CENTRAL LABORATORY
Gandhi Nagar (Near Reserve Bank Quarters), Rajasthan, Jaipur - 302 015
REPORT OF THE BACTERIOLOGICAL EXAMINATION OF WATER

Dated: 4/3/2023

No: Lab/Bact/2022-23/ 11894

To
The Principal,
Kendriya Vidyalaya No. 7,
CISF Campus, Amber,
Jaipur, Rajasthan

The sample was not collected
by this laboratory.


Not valid for Water
Quality Legal Cases

Reference : - Your Application on dated 21.02.2023
GRN NO. : - 72365166 Paid on Date 03.03.2023

Distt: Jaipur
Tehsil: Jaipur
Name of Sample Taker :- Sh. Laxmi Narayan

Sample No.	Date of Collection	Date of Examination	Residual Chlorine mg/l	Area	Particulars of Samples	Coliform Organisms MPN/100 ml	E-Coli Organism (MPN)	Remarks (Satisfactory/ Unsatisfactory)
P:92 ----- 4465	10-Mar-23	10-Mar-23	—	Amber, Jaipur	TW, School Campus, Kendriya Vidyalaya No. 7, CISF Campus, Amber, Jaipur	Nil	Nil	Satisfactory


Remark: 1. Not valid for Water Quality Legal Cases.
2. The Sample was not collected by this laboratory.


Superintending Chemist
PHED, Laboratory, Jaipur
Dated:

No: Lab/Bact/2022-23/

Copy to:

1. The Chief Chemist, PHED, Rajasthan, Jaipur


Superintending Chemist
PHED, Laboratory, Jaipur